



SUNY Oswego Facilities Services Monthly Project Update

June, 2017

Project #	100131
Project Name	ERC-Shineman Laboratory 405 - Ventilation Issues

Project Scope	Modifications to the active ventilation in ERC laboratory Shineman 405 are necessary for the safety of ERC personnel and correct operation of vital instrumentation
---------------	---

Project Phase	C6 - Complete
---------------	---------------

Current Project Coordinator	Kevin Knopp
-----------------------------	-------------

Consultants	SUNY Oswego	
Contractors	SUNY Oswego	

Project Update	6/13/2017 (Knopp) The ventilation issues that existed in room 405 were investigated and identified to be an isolated in-line damper. The M&O staff opened damper and balanced air flow to meet the customer specs.
----------------	---

Project Schedule	Project Start Date	07/06/2016
	Project Finish Date	07/06/2016
	Planning Start Date	
	Planning Finish Date	
	Design Start Date	
	Design Finish Date	
	Construction Start Date*	07/06/2016
	Construction Finish Date*	07/06/2016
	Equipment Start Date	
	Equipment Finish Date	

*Construction Dates Include Warranty Period

Project Costs	Projected Budget	\$0
	Projected Costs	\$0
	Projected Budget Variance	\$0