

2014 Annual OFPC Fire Inspection Top 10 Cited Violations

- Improper use of extension cords
- Swinging fire doors do not close & latch
- Obstructed means and egress including snow & ice
- Excessive & unsafe accumulation of combustible storage
- General electrical hazards-frayed cords, damaged outlets, etc.
- Extinguishers improperly installed and maintained
- Propped open fire doors
- Fire resistance rating not maintained
- Excess combustible storage in mechanical rooms
- Illegal power taps to outlets, electrical