

2014 Annual OFPC Fire Inspection

Top 10 Cited Violations

- Improper Use of Extension Cords
- Swinging Fire Doors Do Not Close & Latch
- Obstructed Means of Egress Including Snow & Ice
- Excessive & Unsafe Accumulation of Combustible Storage
- General Electrical Hazards-Frayed Cords, Damaged Outlets, Etc.
- Extinguishers Improperly Installed and Maintained
- Propped Open Fire Doors
- Fire Resistance Rating Not Maintained
- Excess Combustible Storage in Mechanical Rooms
- Illegal Power Taps to Outlets, Electrical